

DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT 2015 December

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Ran more lab analysis for the city of Coleman.
- Installed a new low pressure blower for the diffused air system.
- Unplugged a clogged floor drain in the garage.
- Installed a new dissolved oxygen probe.
- Repaired the parts washer it need a new fusible link.
- Working on changing the carbon dioxide sensor in the screen room.
- Trimmed trees around outfall.
- Installed a ballast in UV unit number one.
- Trenched in a new conduit for the final effluent PH and dissolved oxygen probe.
- Repaired salt spreader.
- Changed out pump breaker on lift station number 7
- Pulled several lift station pumps at several lift stations.

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Cleaned up well houses and water plant.
- Filled, sampled and put new water tower on line.
- Switch over to the winter air stripper.
- Unplugged chlorine injection point.

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Performed some preventive maintenance on landfill equipment.

Administrative Functions

During the month, the following administrative tasks were performed:

- Conducted interviews for new employee.

- Worked with perceptive controls to get SCADA functioning properly.
- DEQ (Joe Reinke) here for an inspection.
- Made my last trip to Farwell. They now have a licensed operator.