

DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT 2016 January

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Changed out a valve in the diffused air system in lagoon three.
- Replaced the block heater on the generator at the waste water plant.
- Replaced a ballast in a light fixture in the break room.
- Repaired a broken dissolved oxygen probe holder.
- Replaced the emergency shower in the ferric storage room.
- Pulled several lift station pumps at several locations.
- Working on the screen room gas detector it is not functioning very well.

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Repaired the heat tape on the backwash tank discharge pipe.
- Repaired a leaking polyphosphate line.
- Replaced the hour meter on the fluoride pump.
- Bridgeway was here to do generator maintenance.
- Pressure reducing valve was installed backwards in the booster station. Dunigan brothers here to fix and we adjusted and put it back on line.
- Painted pipes in the booster station.

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Filed the landfill report with the DEQ and the Health department.

Administrative Functions

During the month, the following administrative tasks were performed:

- Ryan Cunningham our new operator started working
- Attended a meeting at the landfill in Harrison. They would like to bring us some landfill wastewater.