

# DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT 2016 February

## **Wastewater Treatment Plant**

In addition to their routine duties, our Operators performed the following tasks:

- Perceptive controls here to repair lingering SCADA issues with lift station number ten.
- Performed annual thermometer calibration in lab
- Repaired pipe gate. (Welded a new support bracket on the bottom.)
- Working on the screen room gas detector (CO2 sensor)
- Cleaned out lift station number 7 check valves.
- Started painting water mains in the basement.
- Changed out ferric storage room circuit breaker.
- Made some repairs to the snow blower.
- Pulled several lift station pumps.

## **Water Treatment Plant**

In addition to their routine duties, our Operators performed the following tasks:

- Cleaned out chlorine injection point
- Completed painting and cleanup of the booster station.
- Repaired seal line at booster station.
- Investigated and did maintenance on well 6 starter. It is making a funny noise.
- Switched pressure filters. Put filter number three back online.
- Repaired an electrical outlet in air stripper number three

## **Administrative Functions**

During the month, the following administrative tasks were performed:

- Attended Joint Expo in Lansing
- Ordered a strip heater for the MDOT rest area lift station.
- Ran our annual proficiency testing for the Water lab