

# DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT February 2019

## **Wastewater Treatment Plant**

In addition to their routine duties, our Operators performed the following tasks:

- Pulled the pumps in Lift Station number 2 several times
- Repaired the storm sewer pump station
- Pulled lift station number eight pumps
- Repaired the MDOT lift station
- Pulled lift station number seven pumps.
- Lots of snow removal

## **Water Treatment Plant**

In addition to their routine duties, our Operators performed the following tasks

- Cleaned up the water plant
- Changed out the duck bill in the chlorine injection pump
- Resample WTP for PFOS
- Pulled and cleaned well meters.
- Lots of snow removal.

## **Landfill**

In addition to their routine duties, our Operators performed the following tasks:

- Attended a landfill meeting
- Sampled Terry Shull pond.
- Sent in the landfill report
- Sent the home owners report to Hatton township.

## **Administrative Functions**

During the month, the following administrative tasks were performed:

- Attended joint expo with Tom and Chuck
- Attended Cross connection control class with Chuck
- Attended a USDA meeting