

DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT March 2018

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Repaired two low pressure valves for cell three.
- Burnt some brush at the wastewater plant.
- Replaced the raw sample tube in the influent sample line.
- Fine tuned the ferric feed pump.
- Pulled lift station number two pumps several times.
- Pulled lift station number eight
- Changed out the heater in the MDOT lift station.
- Started working on repairing the slide gate for clarifier number one.
- Stated painting the interior of the wastewater plant.
- Repaired valve operator for lagoon number three air header

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks

- Repaired heater for the booster station.
- Cleaned out chlorine and polyphosphate injection point at the water plant.
- Replaced the belts on the air stripper heater blower.

Administrative Functions

During the month, the following administrative tasks were performed:

- Met with progressive engineering to discuss need repairs to the air strippers.
- Attend a class given by WRD-MDEQ over PFOS contamination in waste water plants.
- Spoke with Prestige place about excessive flushable wipes coming from their facility. They are planning on switching to washable wipes.