

DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT 2016 March

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Finished painting the pipes in the basement.
- Decant the sludge lagoon.
- Some wires burnt up in lift station number 10. A repair was made to get it back working again.
- Did some NPDES sampling for the wastewater plant.
- Replaced the heat strip in the rest area lift station panel.
- Cleaned up pole building.
- Cleaned up plow marks around waste water plant.
- Did some maintenance on lawn mowers to prepare for the summer season.
- Installed a block heater for the WWTP generator.
- Repaired solenoid valve in polymer mixer.
- Purchased a new maintenance program.
- Repaired library lift station
- Kennedy Industries here to do an inferred study on lift station number 10.

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Took some partial chemical samples of some private well around the north water tower. Looking for a new possible water source for the city.
- Cleaned up the interior of the booster station and the new water tower.
- Replaced the Air stripper heater belts.
- Ran a flow test for new water tower.

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Ordered sample bottles for the land fill sampling in may.

Administrative Functions

During the month, the following administrative tasks were performed:

- Sent in the cross connection control report to the DEQ.
- Sent in the IPP report to the DEQ.
- Sent in the PMP report to the DEQ.
- Cleaned chlorine injection point.