

DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT 2016 June

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Finished up lab proficiency testing.
- Ran QA/QC on the new bacteria media and bottles
- Replaced the disconnect on aerator number 14
- Rite way asphalt repaved the drive to the pole building
- Put road gravel down around lagoon number two
- Repaired and installed the gas meter in the screen room

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Worked with Northern Pump and Well to replace our iron removal tower.
- Replaced the overflow screen on the retention tank
- Rebuilt the polyphosphate pump.
- Replaced the polyphosphate injection point
- Repaired chlorine transfer pump.
- Installed new H.O.A. switches for the high service pumps
- Bills Custom Fab here to weld pressure filter number three

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Repaired gate a landfill

Administrative Functions

During the month, the following administrative tasks were performed:

- Worked on annual lab supply bids.
- Mitch Canal transferred to the open operators job at water treatment.
- Hired summertime help.
- Jett pump finished and returned lift station number 6 pump

