

DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT 2016 August

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Took a load of scrap metal to the metal recycling.
- Sprayed the fence line with herbicide.
- Took portable generator to Bridge way in Gaylord for repairs.
- Sent in the gear reducer from screen number 2 for repairs
- Changed out motor on aerator number 11.
- Put gravel on roads around lagoons.
- Installed a new non potable pump.
- Put a new thermo couple in lab muffle furnace.
- Changed out bearings on screen number two.
- Put down some black dirt and seeded around the screw pump.
- Called in for several power outages.
- Pulled several lift station pumps.
- Powered lift stations with the portable generator.

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks

- Tested the distribution system for Total Trihalomethanes and Haloacetic acids.
- Put gravel down on the drives going to the wells.
- Raised a manhole behind water plant.
- Poured a cement slab for well number six.

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Mowed landfill.

Administrative Functions

During the month, the following administrative tasks were performed:

- Sent in the results of the proficiency testing for the lab. We passed all parameters.

