

**DIRECTOR'S
MONTHLY OPERATING REPORT
WATER & WASTEWATER TREATMENT
2016 September**

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

Repaired aerator #5 wiring fault
Recalibrated oxygen sensor in mechanical screen room
Pulled lift station pumps repeatedly to clean rags from impellers
Cleaned force main leaving lift station #7
Replaced liquid detector on influent sampler, and also replaced the pump tubing and cleaned the suction hose
Installed new speed reducer on mechanical screen #2
Mounted an eyewash station in the maintenance garage

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks

Mounted a eyewash station in the WTP chemical storage room
Found the Act-Pak instrumentation at well #9 inoperable and sent it in for repair.
Hauled gravel to north water tower to improve drive and install a turn around

Landfill

In addition to their routine duties, our Operators performed the following tasks:

Monitored Pearson Drilling during the installation of the eight new gas monitoring probes on the 19th
Start the biannual sampling of the landfill wells on the 27th thru the 29th

Administrative Functions

During the month, the following administrative tasks were performed:

Filed the Biosolids report with the DEQ
Hosted a tour from the Clare high school advanced biology class
Dep. Dir. attended a maintenance class in Midland

