

WATER TREATMENT DIRECTOR'S MONTHLY OPERATING REPORT SEPTEMBER 2021

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Performed upkeep on new screw pump
 - Fisher installed grease system
 - Performed oil change
- Tested pH at Advanced Battery Concepts for IPP program
- Turned UV units on
- Maintenance at WWTP property
 - Removed storm debris
 - Lawn maintenance

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Inspected North and South water towers
- Began lead and copper sampling
 - Submitted samples to Trace
- Iron sludge removal
 - Brought in brine truck
 - Removed iron sludge from backwash tanks and placed in drying beds
 - Powerwashed iron filters
- Began cross connections

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Property maintenance at landfill in preparation for testing
- Met with George Shull regarding iron removal system

Administrative Functions

During the month, the following administrative tasks were performed:

- Filed emergency response plan for WTP with EGLE
- Met with EGLE regarding lead and copper
- Submitted IPP PFAS report
- Met with new GFA engineer