

DIRECTOR'S MONTHLY OPERATING REPORT WATER & WASTEWATER TREATMENT NOVEMBER 2015

Wastewater Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Installed a new low pressure blower.
- Ran wastewater lab analysis on whispering pines retirement home.
- Painted the clarifier room garage door.
- Cleaned up and repaired the check valves in lift station number 7.
- Replaced raw sample pump tube.
- Acid washed the fine bubble diffusers
- Ran wastewater samples for the city of Coleman.
- Pulled several lift station pumps at several Lift stations.

Water Treatment Plant

In addition to their routine duties, our Operators performed the following tasks:

- Installed a pump tube on the chlorine feed pump.
- Corpro here to do a cathodic protection inspection on the 4th Street water tower.

Landfill

In addition to their routine duties, our Operators performed the following tasks:

- Received and filled lab analysis from last round of landfill sampling.

Administrative Functions

During the month, the following administrative tasks were performed:

- Worked with perceptive controls on designing the SCADA for the new water tower
- Still filling in at Farwell until they get a licensed operator.